iJRASET

International Journal For Research in
Applied Science and Engineering Technology

INTERNATIONAL JOURNAL FOR RESEARCH

IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

Volume: 6 Issue: I Month of publication: January 2018

DOI: <http://doi.org/10.22214/ijraset.2018.1174>

www.ijraset.com

Call: ☎ 08813907089

E-mail ID: ijraset@gmail.com

Study of Performance Enhancement of Half Effect Vapor Absorption System Using Loop Heat Pipes

Ankit Dwivedi,¹ R S Mishra²

^{1,2}Dept. of Mechanical Engineering, Delhi Technological University, Delhi

Abstract: The Half Effect Vapor Absorption Refrigeration System (VARs) has performance lower than the Single Effect VARs due to several reasons. This research aims to enhance the performance of the half effect system by incorporation of a Loop Heat Pipe (LHP) between the high absorber, high generator and condenser (which is actually replaced by the LHP) to avail the intra-cycle heat exchange. The simulations show that COP I and COP II increase by 64 % and 27 % respectively. Also the LHP condenser temperature T_{Cond} is dependent on the generator temperature T_G . At higher temperatures of TG the increase in COP II is more than that in COP I. Average heat leak from the LHP Q_{Leak} is around 14.38 kW and average heat utilized due to the LHP Q_{Cond} is found to be 79.52 kW.

I. INTRODUCTION

A half-effect vapour absorption system (Fig 3) consists of 2 generators, 2 absorbers, a condenser, an evaporator, 2 pumps, 2 heat exchangers and 3 throttling valves. The half-effect cycle is basically a combination of two single-effect absorption cycles each working at different pressure levels. This system has been developed for relatively low-temperature heat source application. Also the COP of the half-effect system is relatively lower because it rejects more heat than a single-effect cycle. Heat from high temperature external source, transfers to the generator and the absorbers reject heat to the surroundings.

Fig 1: Cyclic process of a Loop heat pipe^[36]

Loop heat pipes (LHPs) are two-phase devices used to transfer heat and maintain temperature. It was developed 1980s for spacecrafts uses. Heat in evaporator vaporizes the working fluid at the wick outer surface, then the vapor flows down the system of grooves and through the vapor line towards the condenser. The fluid condenses in the condenser part. A two-phase chamber (compensation chamber) is present at the end of the evaporator which works at a slightly lower temperature (than the evaporator and the condenser). The lower value saturation pressure in the reservoir draws the condensates and liquid return line. Then the fluid flows into a central pipe where it is fed to the wick.

LHPs are self-primed as the volumes of the reservoir, condenser and vapor and liquid lines are controlled so that fluid is always existing to the wick. The reservoir volume and fluid are set to always have fluid in the reservoir even if the condenser and vapor and liquid lines are full of fluid.

Fig 2: Porous Wick in the LHP.^[35]

The LHPs have an inverted wick, and the vapors are located adjacent to the heated surface. These wicks are prepared by power metallurgy. The outer surface of the wick is in contact with the heated surface. Circumferential and axial grooves are required to generate flow channels for the vapors flow which can be machined in the wick, or to the evaporator body.

II. LITERATURE REVIEW

Fabian Korn et al. [2012] performed several vital experiments on heat pipes to establish it to be one of the most effective procedures to transport thermal energy from one point to another, mostly used for cooling[6]. Sameer Khandekare et al. [2010] performed experiments on the global thermal performance modeling of Pulsating Heat Pipes (PHPs) requires local, spatiotemporally coupled, flow and heat transfer information during the characteristic, self-sustained thermally driven oscillating Taylor bubble flow, under different operating conditions[7]. Jozef Hužvár, Patrik Nemec et al. [2007] used heat pipe, observed its basic principles and operating limits. High temperature heat pipes were evaluated for use in energy conversion applications such as fuel cells, gas turbine re-combustors, and Stirling cycle heat sources, with the resurgence of space nuclear power, additional applications include reactor heat removal elements and radiator elements[8]. R.Z. Wanget al. [2008] added heat pipes in adsorption water chiller or ice maker initials. His work showed that the adsorption refrigerators are very efficient [10]. Pracha Yeunyoungkul et al. [2009] aimed at experimentally investigating the application of a closed loop oscillating heat pipe (CLOHP) as the condenser for a vapor compression refrigeration system[14]. R. Rajashree et al. [1990] went through a numerical analysis of an unsteady, viscous, laminar, incompressible, two dimensional heat and mass transfer, in the vapour gas region of gas loaded circular heat pipe [20]. Da-Wen Sun (1996) performed a detailed thermodynamic analysis of the properties of these binary fluids and expressed in polynomial equations. The performances of three cycles were compared. M.M. Talbi et al. (2000) carried out an exergy analysis on a single-effect absorption refrigeration cycle with lithium-bromide±water as the working fluid pair. E. Kurem et al. (2001) analyzed the Absorption Heat Pump (AHP) and Absorption Heat Transformers (AHT) using ammonia-water and water-lithium bromide solutions. A fundamental AHP and AHT systems was described and explained the operating sequence. R.D. Misra et al. (2002) applied the thermoeconomic theory to the economic optimization of a single effect water/LiBr vapour absorption refrigeration system for air-conditioning application. S.A. Adewusi et al (2004). studied the performance of single-stage and two-stage ammonia–water absorption refrigeration systems (ARSs). They calculated entropy generation of each component and the total entropy generation of all the system components as well as COP of the ARSs. S. Arivazhagan et al. (2006) investigated experimentally on the performance of a two-stage half effect vapour absorption cooling system. The prototype is designed for 1 kW cooling capacity using HFC based working fluids (R134a as refrigerant and DMAC as absorbent). Rabah Gomri et al. (2008) performed exergy analysis of

III. SYSTEMS DESCRIPTION

The diagram illustrates a two-stage cascade refrigeration system. The system is composed of the following components and their interconnections:

- High Stage Components:**
 - High Generator, T_{Hg}** : Receives heat $Q_{H\ Gen}$ and is connected to the High H.Ex (9 to 10) and the High Absorber (11 to 12).
 - High H.Ex**: Heat exchanger between the High Generator and High Absorber.
 - High Absorber, T_{Ha}** : Receives heat $Q_{H\ Abs}$ and is connected to the High H.Ex (11 to 12) and the Low Generator (18 to 19).
- Low Stage Components:**
 - Low Generator, T_{Lg}** : Receives heat $Q_{L\ Gen}$ and is connected to the Low H.Ex (3 to 4) and the Low Absorber (1 to 2).
 - Low H.Ex**: Heat exchanger between the Low Generator and Low Absorber.
 - Low Absorber, T_{La}** : Receives heat $Q_{L\ Abs}$ and is connected to the Low H.Ex (5 to 6) and the High Absorber (18 to 19).
- Refrigerant and Solution Flow:**
 - Strong Refrigerant Loop:** Connects the Condenser (14) to the Evaporator (15) via a valve. The Evaporator is connected to the Low Absorber (16).
 - Strong Solution Loop:** Connects the Low Absorber (17) to the Low Generator (18) via a pump (P).
- Heat Flows:**
 - Q_c : Heat rejected at the Condenser.
 - $Q_{H\ Gen}$: Heat input to the High Generator.
 - $Q_{H\ Abs}$: Heat input to the High Absorber.
 - $Q_{L\ Gen}$: Heat input to the Low Generator.
 - $Q_{L\ Abs}$: Heat input to the Low Absorber.
 - RE : Heat input to the Evaporator.

Figure 4 on the other hand shows the modifications proposed in the above system to have improved performance. There can be a LHP installed between the High Absorber and High Generator removing the heat exchanger and the condenser, thus reducing the size and cost of the system. The LHP acts as the condenser and the heat exchanger altogether. The benefit of high temperature heat transfer will result in decrease in energy and increase in COP_{II}. Also it reduces the requirements in the high generator. There can

The diagram illustrates a two-stage absorption refrigeration cycle integrated with a Loop Heat Pipe (LHP). The cycle components and their connections are as follows:

- High Generation (T_{HG})**: Receives heat input $Q_{H\ Gen}$ at point 10. It is connected to the **High Absorber** at point 11 and the **Low Generator** at point 9.
- High Absorber (T_{Ha})**: Receives the strong solution from the **Low Absorber** at point 12. It rejects heat $Q_{H\ Abs}$ at point 13. It is connected to the **Low Generator** at point 18.
- Low Generator (T_{Lg})**: Receives heat input $Q_{L\ Gen}$ at point 4. It produces vapor at point 3, which enters the **Low H.Ex.** It is connected to the **High Absorber** at point 18.
- Low H.Ex.**: A heat exchanger that preheats the strong solution (point 2 to 1) and cools the weak solution (point 5 to 6). It is connected to the **Low Generator** at point 3 and the **Low Absorber** at point 5.
- Low Absorber (T_{La})**: Receives the weak solution from the **Low H.Ex.** at point 6. It rejects heat $Q_{L\ Abs}$ at point 17. It is connected to the **High Absorber** at point 12.
- Evaporator (T_E)**: Receives heat input RE at point 15. It is connected to the **High Generation** at point 14 and the **Low Absorber** at point 16.
- Loop Heat Pipe (LHP)**: A closed loop system that transfers heat from the **Evaporator** to the **High Generation**. It consists of a **Vapor Line** (top) and a **Liquid Line** (bottom). The **Evaporator** is connected to the LHP at point 15, and the **High Generation** is connected at point 13. The LHP is labeled with Q_{Evap} and Q_{Cond} .

Table 1: Terms Used in Simulation

Terms	Abbreviations
Refrigeration Effect in kW	RE (kW)
Heat rejected in absorber in kW	Q_a (kW)
Heat supplied in generator in kW	Q_g (kW)
Heat rejected in condenser of LHP in kW	Q_{cond} (kW)
Heat absorbed in evaporator of LHP in kW	Q_{eva} (kW)
Absorber Temperature in °C	T_{La}, T_{Ha} (°C)
Generator Temperature in °C	T_{Hg}, T_{LG} (°C)
LHP Condenser Temperature in °C	T_c (°C)
Evaporator Temperature in °C	T_E, T_e (°C)
Heat Rejected in Condenser in kW	Q_C (kW)
First Law Coefficient of Performance	COP_I
Second Law Coefficient of Performance	COP_{II}
Heat Leaked from the LHP in kW	Q_{Leak} (kW)
Percentage Improvement in First Law Coefficient of Performance	% $COP_{I imp}$
Percentage Improvement in Second Law Coefficient of Performance	% $COP_{II imp}$
Improvement in First Law Coefficient of	$COP_{I imp}$

Performance	
Improvement in Second Law Coefficient of Performance	$COP_{II\ imp}$

IV. RESULTS AND DISCUSSIONS

The simulations show the following results. Fig 5 & Fig 6 show the improvements in COP_I and COP_{II} with varying heat utilized in the condenser of LHP (Q_{Cond}) with reference to the performance of the system without modifications. It can be inferred from the Fig 5 that the improvements in COP_I is directly proportional to the heat being utilized. The average improved COP_I , that the simulations show, is around 0.69.

Fig 5: Comparison between COP_I and $COP_{I\ imp}$ plotted with Q_{Cond}

Fig 6: Comparison between COP_{II} and $COP_{II\ imp}$ plotted with Q_{Cond}

The Fig 6 shows that with reuse of heat in the LHP decreases the loss of exergy increasing the COP_{II} . The COP_{II} decreases a little but then it rises steadily similar to the COP_I . Also the heat transfer at high temperatures helps in decreasing the exergy loss. The average enhanced COP_{II} has been calculated to be 0.502.

Moreover the Fig 7 and Fig 8 show the relative comparison between the COP_I & COP_{II} . Fig 7 shows the comparison between the COP_I and COP_{II} with the varying Q_{Cond} . Both rise steadily for the entire range of the Q_{Cond} .

Fig 7: COP_I and COP_{II} plotted with Q_{Cond}

Fig8: Variation of $\%COP_{I imp}$ and $\%COP_{II imp}$ plotted with Q_{Cond}

The fig 8 shows the percentage improvement in the COP_I and COP_{II} with Q_{Cond} . The average rise in the COP_I is 64 %, where as that in COP_{II} is 27 %. In both the figures, COP_I and COP_{II} the rise is parallel.

The Fig 9,10,11,12 show the variation of COP_I and COP_{II} with T_C and T_G . It can be seen that the relation between the two temperatures is linear. Higher the T_G , higher will be the T_C . With high temperatures of heat exchange, the COP_{II} rise is more than the rise in COP_I . Whereas the rise in COP_I becomes flat.

Fig9: Comparison of %age improvements in COP I & COP II varying the T_c

Fig 10: Comparison of %age improvements in COP I & COP II varying the T_g

Fig 11: Comparison of COP I & COP II varying the T_c

Fig 12: Comparison of COP I & COP II varying the T_C

The Fig 13 & Fig 14 show the values of Q_{Cond} & Q_{Leak} with respect T_C and T_G . With increase in the temperatures the heat leaked from the LHP is found to reduce, whereas the heat reusable increases.

Fig 13: Comparison of Q_{Leak} & Q_{Cond} varying the T_C

The T_C is a dependent parameter on T_G directly. As the T_G increases the T_C also increases the heat to be supplied and the maximum temperature up to which it can be transferred also increases. The average Q_{Cond} is observed to be 79.52 kW.

Fig 14: Comparison of Q_{Leak} & Q_{Cond} varying the T_G

Q_{Leak} is found to decrease as the operating temperature increases. The operating temperature increases the heat transfer coefficient hence more heat is transferred in the evaporator of the LHP, reducing the Q_{Leak} . The average Q_{Leak} is calculated to be 14.38 kW.

V. CONCLUSIONS

Through the simulations followings can be the conclusions for the Half Effect VARS:

- COP_I & COP_{II} increase with the Q_{Cond} and the average values for the modified value are 0.69 & 0.502 respectively.
- The average rise in the COP_I is 64 %, where as that in COP_{II} is 27 %.
- Higher the T_G , higher will be the T_C . With high temperatures of heat exchange, the COP_{II} rise is more than the rise in COP_I . Whereas the rise in COP_I becomes flat.
- With increase in the temperatures the heat leaked from the LHP is found to reduce. Average Q_{Leak} is around 14.38 kW.
- The operating temperature increases the heat transfer coefficient hence more heat is transferred in the evaporator of the LHP having the average Q_{Cond} as 79.52 kW.
- The exergetic losses can be reduced, along with the reduction in size of the system, making the system flexible.

REFERENCES

- Saeed, Sedigh , Hamid. Saffari , "Thermodynamic analysis of single effect and half effect absorption refrigeration system" International Journal of Energy & Technology Vol.25 (2011) 1-9.
- S. Arivazhagan , R. Saravanan , S. Renganarayanan , " Experimental studies on HFC based two-stage half effect vapour absorption cooling system" Applied Thermal Engineering Vol. 26 (2006) 1455–1462.
- Gulshan Sachdeva, Ram Bilash, " Thermodynamic Analysis of a Vapor Absorption System Using Modified Gouy-Stodola Equation" International Journal of Computer, Electrical, Automation, Control and Information Engineering Vol:8, No:12, 2014.
- I. Horuz, " A comparison between Ammonia-water and Water-Lithium Bromide solutions in Vapor Absorption Refrigeration Systems" Int. Comm. Heat Mass Transfer, Vol. 25, No. 5, pp. 711-721, 1998.
- Abdul Khaliq, and Rajesh Kumar, " Exergy analysis of double effect vapor absorption refrigeration system" Int. J. Energy Res. 2008; Vol.32:161–174.
- S.C. Kaushika, Akhilesh Arora, " Energy and exergy analysis of single effect and series flow double effect water–lithium bromide absorption refrigeration systems" international journal of refrigeration Vol.32 (2009) 1247 – 1258.
- Rabah Gomri , Riad Hakimi, " Second law analysis of double effect vapour absorption cooler system" Energy Conversion and Management Vol.49 (2008) 3343–3348.
- S.A. Adewusi, Syed M. Zubair, " Second law based thermodynamic analysis of ammonia–water absorption systems" Energy Conversion and Management Vol. 45 (2004) 2355–2369.

- [9] RabahGomri, "Second law comparison of single effect and double effect vapour absorption refrigeration systems" *Energy Conversion and Management* Vol. 50 (2009) 1279–1287.
- [10] R.D. Misra, P.K. Sahoo, S. Sahoo, A. Gupta, "Thermoeconomic optimization of a single effect water/LiBr vapour absorption refrigeration system" *International Journal of Refrigeration* Vol.26 (2003) 158–169.
- [10] M. Belghazi, A. Bontemps, C. Marvillet, "Experimental study and modelling of heat transfer during condensation of pure fluid and binary mixture on a bundle of horizontal finned tubes" *International Journal of Refrigeration* Vol.26 (2003) 214–223.
- [11] M.M. Talbi, B. Agnew, "Exergy analysis: an absorption refrigerator using lithium bromide and water as the working Fluids" *Applied Thermal Engineering* Vol. 20 (2000) 619-630.
- [12] E. Kurem, "A comparison between Ammonia-water and Water-Lithium Bromide solutions in vapour absorption heat transformers" *In. Comm. Heat Mass Transfer*; Vol. 28, No. 3, pp. 421-438, 2001.
- [13] Da-Wen Sun, "Comparison of the performances and NH₃-H₂O, NH₃-LiNO₃ and NH₃-NaSCN Vapor Absorption Refrigeration Systems" *Energy Convers. Mgmt* Vol. 39, No. 5/6, pp. 357-368, 1998.
- [14] Yu.F. Maydanik, "Review Loop heat pipes" *Applied Thermal Engineering* Vol.25 (2005) 635–657.
- [15] Randeep Singh, Aliakbar Akbarzadeh, Masataka Mochizuk, "Operational characteristics of a miniature loop heat pipe with flat evaporator" *International Journal of Thermal Sciences* Vol.47 (2008) 1504–1515.
- [16] T.X. Li, R.Z. Wang, L.W. Wang, Z.S. Lu, C.J. Chen, "Performance study of a high efficient multifunction heat pipe type adsorption ice making system with novel mass and heat recovery processes" *International Journal of Thermal Sciences* Vol.46 (2007) 1267–1274
- [17] Yuan-Ching Chiang, Wen-Cheng Kuo, Chia-Che Ho, Jen-Jie Chieh, "Experimental study on thermal performances of heat pipes for air-conditioning systems influenced by magnetic nanofluids, external fields, and micro wicks" *International Journal of Refrigeration* Vol.43 (2014) 62–70.
- [18] T.X. Li, R.Z. Wang, L.W. Wang, Z.S. Lu, "Experimental investigation of an innovative dual-mode chemisorption refrigeration system based on multifunction heat pipes" *International Journal of Refrigeration* 31 (2008) 1104–1112.
- [19] L. GarousiFarshi a,*, C.A. Infante Ferreira b, S.M.S. Mahmoudi a, M.A. Rosen, "First and second law analysis of ammonia/salt absorption refrigeration systems" *International Journal of Refrigeration* Vol. 40 (2014) 1111-1121.
- [20] T.X. Li, R.Z. Wang, L.W. Wang, Z.S. Lu, J.Y. Wu, "Influence of mass recovery on the performance of a heat pipe type ammonia sorption refrigeration system using CaCl₂/activated carbon as compound adsorbent" *Applied Thermal Engineering* Vol. 28 (2008) 1638–1646.
- [21] Z.S. Lu, L.W. Wang, R.Z. Wang, "Experimental analysis of an adsorption refrigerator with mass and heat-pipe heat recovery process" *Energy Conversion and Management* Vol. 53 (2012) 291–297.
- [22] Behrooz M. Ziapour*, Mohsen Tavakoli, "Performance study on a diffusion absorption refrigeration heat pipe cycle" *International Journal of Thermal Sciences* Vol.50 (2011) 592-598.
- [23] Basant K. Agrawal*, Munawar N. Karimi, "Thermodynamic performance assessment of a novel waste heat based triple effect refrigeration cycle" *International Journal of Refrigeration* Vol. 35 (2012) 1647-1656.
- [24] Behrooz M. Ziapour*, Mohsen Tavakoli, "Performance study on a diffusion absorption refrigeration heat pipe cycle" *International Journal of Thermal Sciences* 50 (2011) 592-598.
- [25] T.S. Jadhav, M.M. Lele, "Theoretical energy saving analysis of air conditioning system using heat pipe heat exchanger for Indian climatic zones" *Engineering Science and Technology, an International Journal* Vol. 18 (2015) 669-673.
- [26] Chengchu Yan, Wenxing Shi, Xianting Li, Shengwei Wang, "A seasonal cold storage system based on separate type heat pipe for sustainable building cooling" *Renewable Energy* Vol.85 (2016) 880-889.
- [27] Matthias H. Buschmann, "Nanofluids in thermosyphons and heat pipes: Overview of recent experiments and modelling approaches" *International Journal of Thermal Sciences* Vol.72 (2013) 1-17.
- [28] P.D. Dunn, D.A. Reay, *Heat Pipes*, Pergamon Press, Oxford, 1993.
- [29] D.Reay, *Heat Pipes-Theory, Design and Applications*, Butterworth-Heinemann, Oxford, Fifth edition 2006.
- [30] Korn, F., "Heat Pipes and its Applications" Project Report 2008 MVK160 Heat and Mass Transport May 07, 2008, Lund, Sweden.
- [31] Rajashree, R., Rao, K.S., "A Numerical Study of the Performance of Heat Pipe" *Indian Journal of Pure and Applied Mathematics*, 21 (1): 95-108, January 1990.
- [32] C.P. Arora, *Refrigeration and Air Conditioning*, Tata McGraw-Hill Publishing Company Limited, Delhi, Third Edition, 2009.
- [33] Ankit Dwivedi, R. S. Mishra, "Thermodynamic Analysis of Heat Pipe Using Ammonia, Water and Ethanol with a View to Being Used in Refrigeration" ISSN 2347 - 3258 *International Journal of Advance Research and Innovation*, Volume 3, Issue 3 (2015) 498-502.
- [34] Ankit Dwivedi, R. S. Mishra, Manjunath K, "Optimization of Vapour Absorption System Using Heat Pipes" ISSN: 2321-9653 *International Journal for Research in Applied Science & Engineering Technology (IJRASET)*, Volume 5 Issue VIII, August 2017, 634-639.
- [35] <http://iusti.univ-provence.fr/document.php?pagendx=11288&project=iusti> [36] <https://www.i-act.com/innovations/heat-pipes/heat-pipe-loops/>

10.22214/IJRASET

45.98

IMPACT FACTOR:
7.129

IMPACT FACTOR:
7.429

INTERNATIONAL JOURNAL FOR RESEARCH

IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

Call : 08813907089 (24*7 Support on Whatsapp)