iJRASET

International Journal For Research in
Applied Science and Engineering Technology

INTERNATIONAL JOURNAL FOR RESEARCH

IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

Volume: 9 Issue: VI Month of publication: June 2021

DOI: <https://doi.org/10.22214/ijraset.2021.35494>

www.ijraset.com

Call: 08813907089

E-mail ID: ijraset@gmail.com

Improvement of Power Quality using a Robust Hybrid Series Active Power Filter

Dasari Vinay¹, Mailarisetti Vinay², Poonem Vamshi Krishna³, S. Ravi Chandran⁴

^{1, 2, 3}U.G Student, ⁴Associate Professor Dept. of EEE, Sreenidhi institute of science and technology, Hyderabad, India,

Abstract: In this paper we are going to see how the DSM PI controller is used to reduce the harmonics in faster. DSM PI controller steps up the voltage to required level. The main aim is to improve the total harmonic distortion.

Keywords: Shunt active filter, hybrid active filters, DSM PI controller

I. INTRODUCTION

Electrical power quality has been a developing concern because of the proliferation of the nonlinear loads, which causes significant increase of line losses, instability and voltage distortion. The ensuing unbalanced current adversely affects each component inside the energy system and equipment. This outcomes in terrible power aspect, increased losses, excessive neutral currents and reduction in standard efficiency. In any case, they are commonly costly and have high working misfortunes. Hereafter to defeat these disadvantages and to improve the pay execution with decreased expense of the APFs, a novel HAPF topology-III is presented by Peng et al. in 1988, in which APF is associated in arrangement with the source just as non-straight load and PPF associated in parallel with the load, which carries on as power factor amendment capacitor is proposed. This topology pulled in substantially more consideration regarding persevere through high load currents and functions as a consonant isolator among source and non-straight load.

A. Objective

To suppress the harmonic distortions created by the non-linear loads in the system and to improve the Total Harmonic Distortion (THD) are the main objectives of this project.

II. POWER SYSTEM HARMONICS

Power system harmonics are whole number products of the basic power system recurrence. Power system harmonics are made by non-straight gadgets associated with the power system. Harmonics are voltage and current frequencies riding over the ordinary sinusoidal voltage and current waveforms. The nearness of harmonics (*both current and voltage*) is seen as 'contamination' influencing the activity of power systems.

The most widely recognized wellspring of consonant mutilation is electronic hardware utilizing switch-mode power supplies, for example, PCs, flexible speed drives, and high-productivity electronic light weights. Consonant waveforms are described by their abundancy and symphonious number. At the point when a sinusoidal voltage is connected to a specific sort of load, in which the load causes the current to differ lopsidedly with the voltage amid each cyclic period.

Harmonics in power systems can turn into the wellspring of an assortment of unwelcome impacts. For instance, harmonics can cause signal impedance, over voltages, information misfortune, and electrical switch disappointment, just as hardware warming, glitch, and harm. Any distribution circuit serving present day electronic gadgets will contain some level of symphonious frequencies. The more prominent the power drawn by nonlinear loads, cause more noteworthy the dimension of voltage bending. Potential issues (or side effects of issues) ascribed to harmonics include:

- A. Malfunction of delicate gear
- B. Random stumbling of circuit breakers
- C. Flickering lights
- D. Very high impartial currents
- E. Overheated stage conductors, boards, and transformers
- F. Premature disappointment of transformers and uninterruptible power supplies .(UPSs)
- G. Reduced power factor

III. HYBRID ACTIVE POWER FILTERS

Specialized confinements of traditional APFs can be overwhelmed with half and half APF designs. They are commonly the mix of essential APFs and uninvolved filters. Crossover APFs, acquiring the upsides of both aloof filters and APFs give improved execution and financially savvy arrangements. The thought behind this plan is to at the same time lessen the exchanging clamor and electromagnetic obstruction.

The possibility of half and half APF has been proposed by a few scientists. In this plan, a minimal effort uninvolved high-pass filter (HPF) is utilized notwithstanding the ordinary APF. The harmonics filtering task is separated between the two filters. The APF drops the lower request harmonics, while the HPF filters the higher request harmonics. The fundamental target of cross breed APF, along these lines is to improve the filtering execution of high-request harmonics while giving a practical low request harmonics alleviation.

These days different half and half APFs utilizing in electronic industry, however the two most noticeable ones are appeared in below figure. The given figure is the system arrangement of the half and half shunt APF. Both the shunt APF and aloof filter are associated in parallel with the nonlinear load. The capacity of the half and half APF would thus be able to be partitioned into two sections: the low-request harmonics are dropped by the shunt APF, while the higher recurrence harmonics are filtered by inactive HPF. This topology fits retrofit applications with the current shunt APF.

Fig:1. Hybrid active power filter

IV. REFERENCE SIGNAL ESTIMATION TECHNIQUES

A standout amongst the most examined programming part (on account of a DSP execution) of an active filter is the symphonious recognition strategy. In short, it speaks to the part that has the ability of deciding explicit signal properties from an info signal (that can be voltage, current or both) by utilizing a unique scientific calculation.

Various calculations developed for the symphonious recognition, which prompted a huge logical discussion on which part the spotlight ought to be put on, the identification precision, the speed, the filter steadiness, simple and reasonable execution, and so forth. The arrangement of these strategies should be possible with respect to the area where the scientific model is created. Hence, two noteworthy bearings are portrayed here, the time space and the recurrence area strategies. The considered reference signal estimation strategies. They can't be considered to have a place with the control circle since they play out an autonomous assignment by furnishing the controller with the required reference for further preparing. This segment exhibits the considered reference signal estimation systems, accommodating every one of them a short portrayal of their fundamental highlights.

A. Recurrence Domain Approach

Reference signal estimation in recurrence space is reasonable for both single-and three-stage systems. They basically got from the guideline of Fourier investigation as pursues.

The principle downside of this strategy is the going with time delay in system factors testing and calculation of Fourier coefficients. This makes it unreasonable for ongoing application with powerfully changing loads. In this manner, this strategy is appropriate for gradually shifting load conditions. So as to make calculation a lot quicker, a few changes was proposed and rehearsed later. In this changed Fourier-arrangement conspire, just the basic part of current is determined and this is utilized to isolate the all-out consonant signal from the tested load-current waveform.

B. Time Domain Approaches

Time-area approaches depend on momentary estimation of reference signal as either voltage or current signal from contorted and consonant dirtied voltage and current signals. These methodologies are appropriate for both single-stage and three-stage systems with the exception of the synchronous-recognition hypothesis and synchronous-reference-outline hypothesis which must be embraced for three-stage systems.

- 1) *Instantaneous Power Hypothesis*: Prompt power hypothesis (and variations) decides the symphonious twisting from the immediate power figuring in a three-stage system, which is the increase of the momentary estimations of the currents and voltages. The figuring's might be done in $\alpha\beta$ -organizes as in the beneath condition and quick reactive power hypothesis, p and q , are decayed into immediate genuine and fanciful powers, separately. The estimation in this square chart may influenced, if the system has zero arrangement segment because of a current unbalance. Thusly, additionally a p_0 part should be added to give a total investigation. Different procedures dependent on a similar standard improve diverse other component, as like the dropping of the unbiased currents, the minimization of the energy stockpiling component, the pre-preparing of the information voltages to keep just the positive succession.
- 2) *Synchronous dq Frame*: Synchronous key -outline is gotten from the space vector change of the information signals, which at First are accomplished in the abc-arranges (stationary reference outline) from the sensors and afterward changed into the - facilitates (pivoting reference outline with basic recurrence) by methods for the Park change (beneath condition). Here the dq outline turns with the key rakish recurrence. Also, in this casing the essential currents are showed up as dc segments and the harmonics as air conditioning signals. The active and reactive parts of the three-stage system are spoken to by the direct and quadrature segments separately. In this hypothesis, the essential segments are changed into DC amounts which can be isolated effectively through filtering. Along these lines, the recognition of the harmonics turns into a matter of evacuating the dc-signal with a High-Pass Filter (with a cutting recurrence between 25 Hz - 120 Hz).

C. The working of APF

An active power filter can be considered as a compensator for power system harmonics. The working of active power filter comprises of mostly three phases. They are:

- 1) *Signal Molding*: Signal molding alludes to the recognition or detecting of harmonics in the power distribution line. The reference signal to be prepared by the controller is the key segment that guarantees the right activity of APF.
- 2) *Inference of Repaying Signal*: The following stage is the deduction of remunerating signal from the upset wave comprises of both basic wave and the consonant substance. It very well may be finished by two unique techniques recurrence area approach and time space approach. Recurrence area approach utilize Fourier change strategy for this reason. While Time area approach utilizes various techniques like Instantaneous Reactive-Power Theorem, Synchronous-Reference-Frame Theorem, Synchronous Detection Theorem, Sine-Multiplication Theorem, step filter strategy and so forth.
- 3) *Age of Gating Signal*: The third stage is the age of gating signal for symphonious concealment. Such a significant number of control procedures like space Vector PWM, dull control, hysteresis current control, one-cycle control, miscreant control, sliding mode control, fluffy control and the fake neural system technique have been acquainted and connected with different arrangements of active power filters. Gating signal generator in the general square outline of APF is utilized for this reason.

V. MATLAB SIMULATION

- A. In this chapter, various waveforms of DSM-PI controller model are simulated in MATLAB Simulink and various input and output waveforms for the different conditions are shown below.
- B. Working of the model
- C. The simulation is connected with a three phase source connected to impedance.
- D. A non-linear load is connected which has diode bridge rectifier connected to RL load.
- E. The series active power filter is connected at point of common coupling using series transformers.
- F. Each single-phase inverter is controlled individually using feedback controller.
- G. The controller comprises of dual sliding mode controller with voltage and current feedback.
- H. The complete simulation is run for 1sec with and without active power filter.
- I. The DSM-PI controller uses adjustable K_p and K_i values for the series active power filter to react faster to the disturbances caused by the non-linear load.
- J. An FFT analysis is carried out from powergui block and compared with response time between PI and DSM-PI controllers.

Fig:2. MATLAB Simulink model for DSM-PI controller

Fig:3.Input Waveforms, VS and IS for DSM-PI controller model

Fig.4 The Output Voltage and Output Current for the DSM-PI model

Fig.5 FFT analysis

Mode of operation	THD%
Without hsapf	22.48%
With hsapf	3.42%

Table 4.1 THD values

VI. CONCLUSION

In this paper, another hearty controller plan for HSAPF has been exhibited. The control configuration is set up by sliding mode controller-2 that determines the identical control law. This control law is especially useful for exchanging design age. The strong ness of the proposed controller has been verified by investigating the presentation under relentless state just as transient state of the power system. With the utilization of this method, the functionalities of the HSAPF are improved. From the got recreations just as exploratory outcomes, the proposed HSAPF has been seen to give efficient current just as voltage symphonious moderation, reference voltage tracking conduct, and reactive power pay with progressively shifting load conditions. Reenactment and exploratory outcomes under a few system working states of load has verified the plan idea of the recommended sliding mode based HSAPF to be exceedingly successful.

VII. ACKNOWLEDGMENT

We would like to express our sincere thanks to our project supervisor Asst. Prof. S. Ravi Chandhran, Department of Electrical Engineering, Sreenidhi Institute of science and Technology for his constant support, timely help, guidance, sincere co-operation during the entire period of my work. We are grateful to him for providing all the necessary facilities during the course of the project work, for the help provided during various stages of the project.

REFERENCES

- [1] Z. Zeng, H. Yang, S. Tang, and R. Zhao, "Objective-oriented power quality compensation of multifunctional grid-tied inverters and its application in microgrids," *Power Electronics, IEEE Transactions on*, vol. 30, no. 3, pp. 1255–1265, 2015.
- [2] A. B. Nassif, W. Xu, and W. Freitas, "An investigation on the selection of filter topologies for passive filter applications," *Power Delivery, IEEE Transactions on*, vol. 24, no. 3, pp. 1710–1718, 2009.
- [3] M. Ali, E. Laboure, and F. Costa, "Integrated active filter for differential-mode noise suppression," *Power Electronics, IEEE Transactions on*, vol. 29, no. 3, pp. 1053–1057, 2014.
- [4] E. R. Ribeiro and I. Barbi, "Harmonic voltage reduction using a series active filter under different load conditions," *Power Electronics, IEEE Transactions on*, vol. 21, no. 5, pp. 1394–1402, 2006.

10.22214/IJRASET

45.98

IMPACT FACTOR:
7.129

IMPACT FACTOR:
7.429

INTERNATIONAL JOURNAL FOR RESEARCH

IN APPLIED SCIENCE & ENGINEERING TECHNOLOGY

Call : 08813907089 (24*7 Support on Whatsapp)