JOURNAL

OF LIVING ARCHITECTURE

A GREEN ROOFS FOR HEALTHY CITIES PUBLICATION

Volume 6 Number 1 Pages 15-30

2019

Thermal Heat Flux Evaluation of Sloped Green Roofs and Shingle Roofs

Serdar Celik^{1*}, Daniel Murphy², Susan Morgan³, Bill Retzlaff⁴

¹Associate Professor, Mechanical and Industrial Engineering, Southern Illinois University Edwardsville

²Graduate Student, Biological Sciences, Southern Illinois University Edwardsville

³Professor, Civil Engineering, Southern Illinois University Edwardsville

⁴Professor, Biological Sciences, Southern Illinois University Edwardsville

*Corresponding Author, scelik@siue.edu

ABSTRACT

This study focused on the evaluation of a modular green roof system designed for residential roofs to determine its thermal performance. The green roof system was installed on roof models with three slope angles: 1°, 20° (5/12 pitch), and 40° (10/12 pitch). Differences in the average temperature of the undersides of the roof decks were compared between green roof models and shingle roof models at the three slope angles. Experimental data were collected for three summer months to compare the cooling load difference of both roof types at all slope angles. A case study was conducted on a residential single-story unit in St. Louis, Missouri. Results showed that a residential green roof system can yield significant energy savings in the summer season. Roof slope angle is also an important factor in heat gain of building envelopes due to its relationship with the sun's incident angle that affects the solar irradiation on the building.

Key Words: *Green roofs, heat flux, energy savings, roof slope, urban heat island effect*

Nomenclature

c_p	specific heat, kJ/kg.K
g	gravitational acceleration, m/s ²
k	thermal conductivity, W/m°C
L	thickness of the roof assembly, m
Q	conduction heat flux, W/m ²
R	thermal resistance, m ² °C/W
T	temperature, °C
u	x-component of velocity, m/s
v	y-component of velocity, m/s

Symbols

α	slope angle, °
β	thermal expansion coefficient, K ⁻¹
ν	kinematic viscosity of air, m ² /s
ρ	density, kg/m ³

Subscripts

c,b	ceiling, bottom
c,t	ceiling, top
r,b	roof, bottom
r,t	roof, top

INTRODUCTION

Due to increasing energy demand and cost, noticeable changes in carbon footprint, and other environmental concerns, has increased motivation for research and policy discussions to address the energy performance of buildings. In the U.S., 48% of the total residential energy consumption comes from heating and cooling (U.S. Department of Energy, 2015). This percentage by itself is sufficiently large to attract attention to the importance of building insulation. While there are many examples of synthetic insulation materials, green roofs offer an alternative, living system. Along with their potential thermal benefits, green roofs are remarkably instrumental in decreasing the urban heat-island effect, reducing storm water runoff, capturing atmospheric carbon dioxide, and increasing the longevity of roofing materials. Green roofs have been gaining popularity worldwide due to regulations and incentives, including in Europe (Li and Yeung, 2014; Berndtsson et al., 2009), North America (Taylor, 2007, TGRTAG, 2011), and Asia (James and Metternicht, 2013).

Building energy savings benefits of green roof applications have been studied in numerous papers in the literature along with theoretical quantification of thermal benefits of green roofs. Sailor (2008) investigated the evaporative cooling and evapotranspiration effects of green roof systems. Liu (2003) and Sidwell et al. (2008) investigated the shading effect of the plant foliage on the roof surface temperature. Celik et al. (2010 and 2011) studied the effects of various growth media and plant types on thermal benefits of green roof systems both experimentally and theoretically. Extensive, intensive, and semi-intensive green roof types were compared by Silva et al. (2016) in Lisbon, Spain. Results demonstrated that energy savings between 20 and

70% with reference to black roofs can be achieved with green roof growth media depths varying from 0.1 m to 0.7 m. Similarly, Ascione et al. (2013) compared the benefits of green roofs and cool roofs for several cities in northern and southern Europe. That study revealed that the green roofs can yield up to 11% energy savings in the summer season for southern European cities and up to 7% savings in the heating season for selected cities in northern Europe. Berardi (2016) looked at the microclimate benefits of green roofs that relate to the urban heat island effect, observing a noticeable decrease in the surrounding ambient temperature around and atop buildings with green roofs.

Green roof applications can reduce the roof temperature in summer seasons by means of direct shading, evapotranspiration, added insulation, and increased thermal mass (Liu and Baskaran 2003, Oberndorfer et al. 2005). Green roofs reduce the thermal flux on the undersides of the roof decks (Liu and Baskaran 2003, Simmons et al. 2008, Teemusk and Mander 2009). By reducing the heat flux through a rooftop and, thereby, reducing the average indoor temperature of a building, green roofs lead to a reduction in the energy demand of a building, especially during the warm season, shown by several energy consumption studies (Liu and Baskaran 2003, 2005, Sonne 2006, Saiz et al. 2006, Sfakianaki et al. 2009).

Comerford et al. (2018) observed that the requirement to use energy efficiency labels as part of an energy performance certificate program on residential energy efficiency in the United Kingdom (UK) included investment; further, this kind of an approach has the potential to improve residential energy savings.

In another UK study, Castleton et al. (2010) investigated the energy savings potential of green roofs and the feasibility of retrofitting and revealed that older buildings especially would benefit from retrofitting given the significant enhancement in roof insulation properties. According to Michelsen et al. (2015), educational programs on thermal insulation can benefit homeowners while addressing the global warming issue.

The objective of this paper is the quantification of the thermal benefits of sloped green roofs compared with sloped shingle roofs, which are considered as the reference case.

EXPERIMENTAL SETUP AND METHOD

Experimental Setup

Eighteen residential roof models were constructed for testing. Roof decks were ½ inch (1.3 cm) thick treated plywood measuring 8 feet by 4 feet (2.44 m by 1.22 m) with 2 inch x 6 inch lumber (5.1 cm by 15.2 cm) fastened around the bottom edge of each deck and three 2 inch x 6 inch joists spaced across the underside of each deck at 2 feet (61 cm) spacing. Frames were constructed to raise the roof and position them at one of three slope angles: 1°, 20° (5/12 pitch), and 40° (10/12 pitch). Upper surfaces of all roof decks were covered in roofing paper and shingled with light gray, composite asphalt shingles. Nine of the 18 roof models (three models at each of the three slope angles) were fitted with a modular green roof system. The green roof modules were high-density polyethylene, knit fabric bags called Steep Paks®, which were

designed and manufactured by Green Roof Blocks™ (St. Louis, MO). The modules were 10 inches wide and 32 inches long (25.4 cm by 81.3 cm) and filled to a maximum depth of 5 inches (12.7 cm) with blended growth media consisting of 80% Arkalyte by volume (Bussen Quarries, St. Louis, MO; 6 mm – 9 mm expanded clay aggregate) and 20% composted pine bark by volume (River City Landscape, Sauget, IL). Twelve Steep Paks® modules (four rows with three modules in each row) were fastened to each of the nine roof decks with nylon anchor straps that were integrated into the shingles and nailed to the roof decks.

All of the roof models were oriented so that the roof surfaces were facing roughly south (215° SW) in order to maximize sun exposure. The 18 roof models were divided equally into three replications in a completely randomized design. Each replication included two roofs at each slope angle, one of which was fitted with Steep Paks® modules and the other left as a conventional shingled roof (Figs. 1 and 2).

Figure 1 Experimental layout of residential roof models.

Figure 2 Residential roof models.

A mix of seven *Sedum* species (*S. kamtschaticum*, *S. reflexum*, *S. sexangulare*, *S. album*, *S. spurium*, *S. floriferum* 'Weihenstaphaner Gold', and *S. immergruncheon*) were planted. Four small holes were cut in the top of each module, evenly spaced across the length of the module, in order to plant the plugs. Approximately 8 grams of natural organic fertilizer with an N-P-K rating of 5-4-5 was placed in each hole before planting. The plants were irrigated one to two times a week for several weeks to aid establishment. Later on, long-term fertilizer with an N-P-K rating of 18-5-10 was broadcast evenly across the green roof packs.

Method

In this section, methods for plant coverage and thermal measurements are discussed. Plant coverage was quantified using a modified dot grid system. The dot grid measured about 20 inches by 16 inches (50.8 cm by 40.6 cm) and had 80 open circles (10 rows of 8 circles each) which were 1.5 inches (3.8 cm) in diameter. The two middle rows of vegetated modules on each green roof model were divided into six equal sections the size of the dot grid. The dot grid was placed over each section, and open circles in the dot grid were counted. Circles were considered open if less than 50% plant material was showing. Percent plant coverage was calculated by using the equation: $[(80 - \text{\# of open circles}) / 80] * 100$.

A Red Dragon GT-1000 non-contact infrared thermometer (temperature range -50° to 400°C, accuracy +/-2%, distance to spot size ratio 9:1) was used to measure the temperatures of the undersides of the roof decks. Measurements were made by aiming the thermometer at the marks from a distance of approximately 2 feet (61 cm). Temperatures were recorded once every other week at sunrise, midday, and sunset during June to August 2010.

Thermal measurements collected during the summer season were used to evaluate the potential air-conditioning energy savings. Data recorded during the warmest and coolest measurement dates of the study period were also analyzed. A one-way ANOVA for a completely randomized design was used to test for thermal differences between the green roof decks and the control roof decks and between the three slope angles. A Tukey's post-hoc test was used to rank the differences between the treatments at an alpha level of 0.05 (Proc GLM, SAS version 9.3).

Heat gain through both roof systems was analyzed based on the heat flux through the roof into the attic and then to the inside room air of the residential unit through the ceiling. A schematic of the heat transfer analysis can be seen in Fig. 3. Governing equations for these illustrations are given in equations (1-3).

Figure 3 Schematic of heat gain analysis through (a) shingle roof, (b) green roof.

Continuity:

$$\frac{\partial u}{\partial x} + \frac{\partial v}{\partial y} = 0 \quad (1)$$

x-momentum:

$$u \frac{\partial u}{\partial x} + v \frac{\partial u}{\partial y} = \nu \frac{\partial^2 u}{\partial y^2} + \beta g (T_{r,b} - T_{air}) \cos \alpha \quad (2)$$

Energy:

$$\rho c_p \left(u \frac{\partial T}{\partial x} + v \frac{\partial T}{\partial y} \right) = k \frac{\partial^2 T}{\partial y^2} \quad (3)$$

In equation (3), k is the effective thermal conductivity which can be obtained using the R-value of the roof assembly including all layers involved.

$$k = \frac{L}{R} \quad (4)$$

where R is the thermal resistance that accounts for all layers, and L is the total thickness of the roof system.

Case Study

An energy savings analysis for a single-story residential unit of 1200 ft² roof area was performed theoretically using a green roof and a standard shingled roof (Fig. 4). St. Louis, MO, was selected as the location.

Figure 4 Illustration of the residential unit having (a) shingle roof, (b) green roof.

Cooling loads from the ceiling only resulting from the different types of roofs (green vs. shingle) at different slopes (1°, 20°, and 40°) were calculated based on the heat gain through the roof. The analysis was performed for a ceiling with an R-value of R-38 (6.69 m²°C/W), which satisfies the requirements dictated by International Energy Conservation Code (2012 IECC) for climate zone 4, which is adopted by City of St. Louis Building Division. This R-value corresponds to a U-value of 0.149 W/m²°C, which was used in the heat gain analysis through the roofing systems tested in the experimental study. Roof areas were calculated at different roof slopes for the fixed base area of 1200 ft². An indoor design temperature of 20°C was assumed for the cooling load analysis.

RESULTS

Plant coverage was measured to observe the effect of amount of vegetation over the green roof system. During the study period (September 24, 2010 – May 29, 2011), percent plant coverage increased on the 1° green roof decks from 30.2% in March 2010 to 84.7% in July 2010 and then dropped to 66.4% in August 2010 due to drought stress and summer dormancy. In March through May 2011, percent plant coverage on the 1° green roof decks increased from 52.9% to 82.9%. The 20° and 40° green roof decks had lower percent plant coverage compared to the 1° green roof decks (Fig. 5) and percent plant coverage followed a trend similar to the 1° green roof decks throughout the study period. Percent plant coverage between the 20° and 40° green roof decks during any month of the study period (Fig. 5) was not considered statistically different.

Figure 5 Mean percent plant coverage on green roof decks at each slope angle during March – August 2010 and March – May 2011. On average the green roof models at the 1° slope angle had significantly greater percent roof coverage than the green roof models at the 20° and 40° slope angles on each measurement date, and there were no differences between the 20° and 40° slope angles for any of the measurement dates ($p < 0.05$). Error bars represent ± 1 se.

An analysis of covariance was conducted in order to determine if percent plant coverage influenced the temperature of the undersides of the green roof decks. Vegetation coverage in the spring was also recorded to observe the change in time. Mean percent plant coverage during the spring included March through May 2010 and March through May 2011 data, and the mean percent plant coverage in the summer analysis included June through August 2010 data (Fig. 6). Percent plant coverage was found to influence the average temperature of the undersides of the green roof decks at sunrise and midday; and no correlation was found at sunset ($p < 0.05$).

Figure 6 Mean percent plant coverage on green roof decks at each slope angle during spring (March – May 2010 and March – May 2011), and summer (June – August 2010). Error bars represent ± 1 se.

On the thermal performance analysis side, the summer analysis includes the means of the biweekly thermal measurements recorded during June through August 2010 (Fig. 7a-c). On average the undersides of the green roof decks compared to the control roof decks were 0.2°C warmer at sunrise, 6.1°C cooler in at midday, and 0.7°C warmer at sunset (Fig. 7c). Heat flux from sunrise to sunset from the undersides of the green roof decks was smaller than from the control roof decks. The average temperature of the undersides of the green roof decks increased 15.1°C from sunrise to midday and then decreased 6.7°C by sunset. Because the heat flux was larger for the control roofs during the same period, the temperature of the undersides of the decks increased 21.7°C from sunrise to midday and then decreased 13.8°C by sunset (Fig. 7c).

Figure 7 Mean temperature of the undersides of the green and control roof decks at each slope angle at sunrise, midday, and sunset for the summer season including biweekly measurements taken during June – Aug 2010. (a) compares the slope angles of the green roof decks, (b) compares the slope angles of the control roof decks, (c) compares green roof decks with control roof decks. Note that an (*) on the figure indicates a significant difference between treatments ($p < 0.05$) for a single time of day. P-values at sunrise, midday, and sunset are provided in Table 2.

The warmest measurement date of the study period was July 23, 2010, on which the air temperature was 34°C at midday. On this day, the average temperature of the undersides of the green roofs decks was 38.4°C at midday (Fig. 8a), which, while warmer than the air temperature, was 5.7°C cooler than the undersides of the control roof decks (Fig. 8b). Small differences occurred between the average temperatures of the undersides of the green roof decks and the control roof decks at sunrise or sunset (Fig. 8c). These results are similar to other studies that found significantly lower temperatures on the underside of green roof models or in

the indoor temperatures of models/buildings with green roofs compared to conventional roofs (Laar and Grimme 2006, Sfakianaki et al. 2009, Simmons et al. 2008, Sonne 2006).

Figure 8 Mean temperature of the undersides of the green and control roof decks at each slope angle at sunrise, midday, and sunset for July 23, 2010. (a) compares the slope angles of the green roof decks, (b) compares the slope angles of the control roof decks, (c) compares green roof decks with control roof decks. Note that an (*) on the figure indicates a significant difference between treatments ($p < 0.05$) for a single time of day. P-values at sunrise, midday, and sunset are provided in Table 2.

The average temperature of the underside of the green roof deck was cooler compared to the control roof deck at midday during the whole summer season due to the shading, thermal resistance, and evapotranspiration effects of the added vegetation consisting of a mix of *Sedum* species (Table 1). Change in temperature was determined by subtracting the average

temperature of the underside of the green roof deck from the average temperature of the underside of the control roof deck.

Table 1

Temperature difference between shingled and green roof decks at sunrise, midday, and sunset times during the study period.

Analysis Period	Change in Temperature (°C)		
	Sunrise	Midday	Sunset
Summer (average)	-0.2	6.1	-0.7
July 23, 2010 (average)	0.1	5.7	-0.3
July 23, 2010 (max)	0.6	9.1	1.5

Table 2

Thermal measurements for sunrise, midday, and sunset (p-values) for Figure 7a-c and Figure 8a-c. Note that an (*) indicates a significant difference between treatments ($p < 0.05$) for a single time of day.

Figure	Sunrise	Midday	Sunset
7a	0.4643	0.9852	0.0159*
7b	0.5258	0.3822	0.2987
7c	0.0044*	0.0001*	0.0001*
8a	0.1086	0.2756	0.0213*
8b	0.5732	0.5432	0.6008
8c	0.4303	0.0001*	0.7844

For the case study, heat gains through both roof systems at each of the three angles were examined. Fig. 9 plots the difference in average temperatures for control (shingle) and green roof systems during the daytime. Instantaneous heat flux during this time is proportional to the temperature measurement recorded at a given time. The red colored region in the figure can be interpreted as the integration of the heat flux difference per the overall heat transfer coefficient value of the roof within the time frame from sunrise to sunset.

Figure 9 Difference in temperature readings due to vegetation underneath the control (shingle) and green roofs over the period of daytime between sunrise and sunset.

It is known that the amount of cooling energy consumption will vary as the set temperature is changed. The contribution of the ceiling to the cooling load of the selected residential unit was calculated based on the experimental data and an indoor design temperature of 20°C. The key point in this analysis is that calculated results reveal the cooling load differences of green and shingled roofs at different slopes. Calculated results in Table 3 reveal the cooling load differences of green and shingled roofs at the three slope angles studied.

As can be seen from the values in Table 3, there are two findings for this case study.

1. Green roofs yield less cooling load to the residential unit through the ceiling during the daytime (between sunrise and sunset) compared to shingled roofs,
2. For a given roof system, cooling load per unit roof area increases as the slope of the roof gets closer to 16° which receives the highest solar irradiation in St. Louis during the summer season.

While the total roof cooling load seems to be increasing with the increasing slope angle, it should be noted that this is mainly because a 40° sloped roof on a residential unit with 1200 ft² base area has more surface area than a 20° or 1° sloped roof for the same amount of base area. The reason for the increase in cooling load per unit surface area when the slope angle is 20° can be attributed to the maximum solar irradiation being observed at 16° as explained above. While the shingle roof seems to reflect this change more obviously, the green roof system seems not to show much of a difference between 1° and 20° slopes. This result might be due

to possible differences in moisture content, plant coverage and/or the leaf area index of the green roof systems.

Table 3

Calculated cooling loads through the ceiling during the daytime for a selected indoor temperature of 20°C.

Parameter	Green Roof			Shingle Roof		
Slope angle	1°	20°	40°	1°	20°	40°
Roof area (ft ²)	1200	1300	1562	1200	1300	1562
Roof area (m ²)	111.5	120.8	145.1	111.5	120.8	145.1
Roof cooling load during daytime, sunrise to sunset (kW/daytime)	0.031	0.034	0.040	0.063	0.069	0.081
Roof cooling load per unit roof area (W/m ² /day)	0.280	0.280	0.276	0.563	0.571	0.556
Seasonal* cooling energy consumption per unit area (kWh/m ²)	0.365	0.365	0.360	0.735	0.745	0.726

* Covers the summer period during which data was collected (June-August 2010)

These findings agree with a study by Conley (2013), where it is reported that the green roofs were cooler than the shingle roofs and, within the green roof samples, 1° and 40° sloped roofs performed better than the 20° sloped roof on average. Conley's study was also experimental in which the surface temperatures of the same samples were recorded from above the roofs. A thermal camera was used in the experimental analysis. Roof cooling loads during the daytime for all six combinations are plotted in Fig. 10. Cooling loads per unit roof area are illustrated in Fig. 11.

Fig. 10. Residential roof cooling loads for the total roof area of each sample model.

Fig. 11. Residential roof cooling loads per unit roof area of each sample model.

CONCLUSION

The average temperature under the sloped residential green roof deck covered with *Sedum* species had less heat flux than the average temperature under the shingled roof deck through the study period. At midday, the average temperature under the green roof deck was also 6.1°C cooler than the average temperature under a conventional sloped shingled roof throughout the study period. At sunrise and sunset the average temperature of the underside of the green roof decks was 0.2 to 0.7°C warmer.

Vegetation coverage was found to have a correlation with the thermal performance. As the plant coverage increased, cooler temperature readings were recorded during sunrise and midday which can be attributed to shading effect and evapotranspiration cooling potential of the *Sedum* species.

Cooling load per unit roof area was observed to increase as the slope of the roof approached to 16°, which receives the highest incident solar radiation in St. Louis during the summer season. These experimental results were found to be in agreement with another experimental study using the same roof models in which temperatures were recorded using a thermal imaging camera.

Calculated results from the case study conducted on a single-story residential unit with a base area of 1200 ft² showed that the cooling load from the roof only is twice as much from shingle roofs as green roofs. This result indicates energy savings via utilization of green roofs can be quantifiable, depending on the total roof area, geographic location of the residential unit, indoor temperature setting, and utility prices.

LITERATURE CITED

- Ascione, F., Bianco, N., De Rossi, F., Turning, G., Vanoli, G. P. 2013. Green roofs in European climates. Are effective solutions for the energy savings in air-conditioning? *Applied Energy* 104:845-859.
- Berardi, U. 2016. The outdoor microclimate benefits and energy saving resulting from green roofs retrofits. *Energy and Buildings* 121:217-229.
- Berndtsson, J. C., Bengtsson, L., Jinno, K. 2009. Runoff water quality from intensive and extensive vegetated roofs. *Ecological Engineering* 35:369-380.
- Celik, S., Morgan, S., Retzlaff, W. A. 2010. Energy conversation analysis of various green roof systems. In: *Proceedings of the IEEE Green Technologies Conference*. Grapevine, TX.
- Celik, S., Morgan, S., Retzlaff, W. A., Once, O. 2011. Thermal insulation performance of green roof systems. In: *6th International Green Energy Conference*. Eskisehir, Turkey.
- Comerford, D. A., Lange, I., Moro, M. 2018. Proof of concept that requiring energy labels for dwellings can induce retrofitting. *Energy Economics* 69:204-212.
- Conley, K. 2013. "Thermal analysis of residential green roof systems", Master's Thesis, Southern Illinois University Edwardsville.
- James, N., Metternicht, G. 2013. How to grow a green roof industry. In: *Cities Alive 11th Annual Green Roof and Wall Conference Proceedings*. San Francisco, CA.
- Laar, M., Grimme, F. W. 2006. Thermal comfort and reduced flood risk through green roofs in the tropics. In: *PLEA2006: 23rd Conference on Passive and Low Energy Architecture*. Geneva, Switzerland.
- Li, W. C., Yeung, K. A. 2014. A comprehensive study of green roof performance from environmental perspective. *International Journal of Sustainable Built Environment* 3(1):127-134.

- Liu, K., Baskaran, B. 2003. Thermal performance of green roofs through field evaluation. In: *Proc. of 1st North American Green Roof Conference: Greening rooftops for sustainable communities*. Chicago, IL.
- Liu, K., Baskaran, B. 2005. Thermal performance of extensive green roofs in cold climates. National Research Council Canada. NRCC-48202.
- Michelsen, C., Rosenschon, S., Schulz, C. 2015. Small might be beautiful, but bigger performs better: Scale economies in green refurbishments of apartment housing. *Energy Economics* 50:240-250.
- Oberndorfer, E., Lundholm, J., Bass, B., Coffman, R. R., Doshi, H., Dunnett, N., Gaffin, S., Köhler, M., Liu, K. Y., Rowe, B. 2007. Green roofs as urban ecosystems: Ecological structures, functions, and services. *BioScience* 57:823-833.
- Retzlaff, W. A., Ebbs, S., Alsup, S., Morgan, S., Woods, E., Jost, V., Luckett, K. 2008. What is that running off of my green roof? In: *Proc. of 6th North American Green Roof Conference: Greening rooftops for sustainable communities*. Baltimore, MD.
- Retzlaff, W. A. 2010. Building green together. *Living Architecture Monitor* 12:35.
- Sailor, D. J. (2008) A green roof model for building energy simulation programs. *Energy and Buildings* 40:1466-1478.
- Saiz, S., Kennedy, C., Bass, B., Pressnail, K. 2006. Comparative life cycle assessment of standard and green roofs. *Environmental Science and Technology* 40:4312-4316.
- Sfakianaki, A., Pagalou, E., Pavlou, K., Santamouris, M., Assimakopoulos, M. N. 2009. Theoretical and experimental analysis of the thermal behavior of a green roof system installed in two residential buildings in Athens, Greece. *International Journal of Energy Research* 33:1059-1069.
- Silva, C., Gomes, M. G., Silva, M. 2016. Green roofs energy performance in Mediterranean climate. *Energy and Buildings* 116:318-325.
- Simmons, M. T., Gardiner, B., Windhager, S., Tinsley, J. 2008. Green roofs are not created equal: the hydrologic and thermal performance of six different extensive green roofs and reflective and non-reflective roofs in a sub-tropical climate. *Urban Ecosystems* 11:339-348.
- Sonne, J. 2006. Evaluating green roof energy performance. *ASHRAE Journal* 48:59-61.
- Taylor, D. A. 2007. Growing green roofs, city by city. *Environmental Health Perspectives* 115(6):A307-A311.
- Teemusk, A., and Mander, U. 2009. Green roof potential to reduce temperature fluctuations of a roof membrane: A case study from Estonia. *Building and Environment* 44:643-650.
- U.S. Department of Energy website, <https://energy.gov/public-services/homes/heating-cooling>, Accessed March 17, 2018.